230002349837

中国认可
国际互认
检测
TESTING
CNAS L0230

检 测 报 告

TEST REPORT

BETC-T4AC-2025-01928(EN)

产品名称
Name of Product ECONICLAY COVERING

委托单位
Client PHOMI HOLDING CO., LTD.

检验类别
Test Category Commission Testing

建研院检测中心有限公司
CABR TESTING CENTER CO.,LTD.

国家建筑工程质量检验检测中心
National Center for Quality Inspection & Test of Building Engineering

2025-05904

建研院检测中心有限公司

CABR TESTING CENTER CO., LTD

国家建筑工程质量检验检测中心

NATIONAL CENTER FOR QUALITY INSPECTION & TEST OF BUILDING ENGINEERING

委托编号(Commission No.):2025-05904

报告编号(No. of Report):BETC-T4AC-2025-01928(EN)

委托单位 (Client)		PHOMI HOLDING CO., LTD.		
地址 (ADD.)		/	样品编号(NO.)	T4AC-2025-01928
样品 (Sample)	名称(Name)	ECONICLAY COVERING	状态(State)	Normal
	商标(Brand)	PHOMI	规格型号 (Type/Model)	/
生产单位 (Manufacturer)		PHOMI MCM CO., LTD.		
送样日期 (Date of delivery)		Jun. 20, 2025	数量 (Quantity)	10 pieces
工程名称 (Name of engineering)		/		
检测 (Test)	项目 (Item)	Frost resistance	地点 (Place)	Pinggu lab
	仪器 (Instruments)	Freeze-thaw testing machine, Electric thermostatic drying oven, Working glass-stem thermometer	日期 (Date)	Jul. 24, 2025～ Oct. 28, 2025
检测依据 (Test based on)		JG/T 25-2017 *Test method for temperature change resistance of architectural coatings*		
判定依据 (Criteria based on)		/		

检测结论 (Conclusion)

Through testing, the test results of item for the sample are detailed on page 2 of the report.

(Following blank)

备注 (Remarks)	When there are differences in understanding between the Chinese and the English report, the Chinese report shall prevail.

批准 (Approval)	审核 (Verification)	主检 (Chief tester)	联系电话 (Tel.)	报告日期 (Date)
姚	孙俊	张继仁	010-84283858	Nov. 10, 2025

序号 (No.)	检测项目 (Test item)	检测依据 (Test method)	技术指标 (Technical index)	检测结果 (Test result)	单项评定 (Evaluation)
1	Frost resistance (100 cycles, -40℃)	JG/T 25-2017	/	The surface of the sample shows no cracks, chalking, delamination, or other damage phenomena	/

（Following blank）

备注 Remarks	As required by the entrusting party, the number of freeze-thaw cycles for frost resistance is 100, and the freezing temperature is -40℃.